



ICEPAG 2014
April 1-3
Newport Beach, California

Fine PM Emission Factors for Gas Turbine Engines


Glenn C. England
Principal Consultant
ENVIRON International Corporation
Irvine, California 92629



Overview

- Particulate matter (PM) & regulations
- PM Emissions from gas-fired engines
- Emission factors
- Measurement influences & impacts

*We need better measurements of PM
emissions from gas-fired sources*






Why Are Fine PM Emissions from Gas Turbines Relevant?

- Increasing natural gas use for power generation
- Typical 500 MW NGCC plant “emits” ~30-50 tpy
 - All submicron aerosols
- New Source Review
 - 10 tons/year PM2.5 Prevention of Significant Deterioration threshold
 - triggers modeling, technology, offset requirements = time, \$
 - Includes filterable and condensable PM
- Impediment to licensing new power plants in California due to lack of PM10/2.5 offsets
- Evolving interest in human health effects of “ultrafine” PM and nanoparticle emissions



Particulate Matter






PM10 and PM2.5

- Definitions - 40 CFR 51, §51.50:
 - *Filterable PM2.5/PM10 : Particles that are directly emitted by a source as a solid or liquid at stack or release conditions and captured on the filter of a stack test train.*
 - *Condensable PM: Material that is vapor phase at stack conditions, but which condenses and/or reacts upon cooling and dilution in the ambient air to form solid or liquid PM immediately after discharge from the stack.*
- Particulate matter is defined by the test methods used to measure it!



Natural Gas-Fired Combined Cycle


- Gas turbines & steam turbines
 - Brayton+Rankine
 - “2 on 1” or “3 on 1” blocks
 - ~500-800 MW/block
 - Duct burners
 - Thermal efficiencies ~55->60%
- Emissions controls
 - Lean pre-mix combustors
 - SCR
 - 2-5 ppm NO_x limits
 - CO oxidation catalysts






IGCC with CO₂ Separation

Coal, Petcoke,
etc.





PM2.5 Sources




- Incomplete fuel combustion (carbon conversion to soot, organics)
- Combustion and post-combustion conversion of sulfur (& chlorine) to acid aerosols & salts
- Vaporization and condensation of volatile elements
- Transmission of non-volatile elements
- Corrosion/erosion of system components
- Aerosol nucleation, condensation, accumulation and breakup




Effect of CO₂ (and S) Separation

NGCC - Natural Gas




IGCC - Low Carbon Fuel





PM Measurements - traditional

- Hot filter/impingers
 - Collect filterable & condensable separately (?)
 - Dry & weigh filters, evaporate & dry probe/cyclone rinses
 - Organic extraction, evaporate & weigh impinger residues



EPA Methods
201A/202 (2010)


EPA Method 5
State & local
variations

*High bias due to measurement artifacts can be significant
(dissolved gases e.g. O₂, SO₂, NH₃, VOC, HCl → solid residues)*



AP-42 PM Emission Factors - GTs


- Ch. 3.1, gas turbines, natural gas (April 2000)
 - EPA Methods 5 and WDNR 5
 - 5 tests, 4 units 1994-1996
- Total PM 0.0065 lb/MMBtu
 - cPM is 71% of total
 - Uncertainty >100%





Measured Gas Turbine PM Emissions


Impinger catch dominates measured emissions






Measured Gas Turbine PM Emissions

Lower emission rate for larger units (?)






Condensable PM Speciation Method 202 (1991)





Dilution Methods




EPA CTM 039 (2004)

- Stirred jet mixing cone
- Dilution ratio 10-40
- Dilution air <50% RH, 80°F
- Mixing residence time 0.2 sec
- Diluted sample <85°F
- Water & acetone recovery rinses required
- Method 5 gravimetric analysis
 - 0.1 mg balance
 - Evaporate & dry rinses
 - Dry & weigh filter



Dilution Methods

ISO 25597 (2013)




- **(Parallel jet mixing)**
- **Dilution ratio ≥ 20**
- **Aging residence time 10 sec**
- **Diluted sample RH $<70\%$**
- **PM2.5 cyclone after aging**
- **Ambient air gravimetric analysis**
 - **0.001 mg balance, equilibrate @ 20-25°C, 45-55% RH**
- **Recovery rinses (test or run)**



Dilution Methods vs. 201A/202-1990


- Dilution filter results consistently much lower than M201A/202-1990 results in side-by-side tests at 7 different gas-fired sources
- Two different dilution methods
 - Modified EPA CTM 39 (2008)
 - "ISO 25597" (2001-2003)
- M202 (1991) iced impingers
 - sulfate artifact adds significant positive bias
- Blanks and samples typically indistinguishable
 - Concentrations at measurement "noise" level






PM2.5 Emission Factors – Dilution Method

AP-42






Detection & Quantification






Detection Limits

- 500 MW NGCC Block
- Fuel sulfur < 1 ppm
 - low driving force for SO₂ artifact
- EPA Methods 201A/202
- Paired trains, 4 runs
 - 8 samples, 2 train blanks
 - Blanks & samples similar
- Measured emissions are below detection & quantitation limits
 - Facility permit limit between LOD and LOQ





NGCC Stack PM2.5: Dilution Results



Stack and ambient air PM2.5 concentrations are similar



Summary

- Current AP-42 factors for gas-fired sources
 - Few sources
 - High uncertainty
 - Old, problematic methods
- EPA Methods 201A & 202 (& similar methods) remain problematic for gas-fired sources
 - Lack sufficient sensitivity
 - Blank levels are significant – not due to reagent contamination!
 - New Method 202 reduces but doesn't eliminate artifacts
- Dilution methods offer advantages for gas-fired sources
 - Greater accuracy due to absence of SO₂ and VOC artifacts & greater analytical sensitivity
 - Resulting PM2.5 emission factors are ~1/10 or lower of those based on hot filter/cooled impinger methods e.g. AP-42



Summary (cont'd)

- Dilution method evaluation & refinement
 - Refine & validate test conditions & procedures
 - Reduce background levels in dilution air & probe recovery solvents
 - Reduce organic carbon artifacts
 - Reduce relative variability of results
- More tests
 - Document method performance in field
 - Develop robust emission factors

We need better measurements of PM emissions from gas-fired sources



Questions?



Glenn England

gengland@environcorp.com

949-798-3643