



EMO[®]

August 1, 2013

Bobby I.T. Chen
Client Program Manager




MATS Overview



Subcategory	Total Filterable Particulate Matter (PM)	Hydrogen Chloride (HCl)	Mercury (Hg)
Existing coal-fired unit designed for coal > 8,300 Btu/lb	0.030 lb/MMBtu (0.30 lb/MWh)	0.0020 lb/MMBtu (0.020 lb/MWh)	1.2 lb/TBtu (0.010 lb/GWh)
Existing coal-fired unit designed for coal < 8,300 Btu/lb	0.030 lb/MMBtu (0.30 lb/MWh)	0.0020 lb/MMBtu (0.020 lb/MWh)	4.0 lb/TBtu (0.040 lb/GWh)

- ▶ Mercury and Air Toxics Standard (MATS) published on 2/16/2012, which became effective 60 days later. Compliance needs to be demonstrated by the 1st quarter of 2015
- ▶ Final PM limit for Filterable PM only (per EPA Method 5)
- ▶ Use of the alternate SO₂ limit is not allowed if EGU does not have some form of FGD system and SO₂ CEMS installed.
- ▶ Where alternate limits are designated with “or” in Table 2 Section 1 of MATS, these pollutants may be used in lieu of pollutants listed in same subsection (e.g. Total non-HAPs may be used in lieu of Filterable PM).
- ▶ The Hg limit is **based on a 30-day boiler operations rolling average**

EMO[®] Injection General Arrangements




- ▶ Injecting chemical: EMO[®] chemical additives

Mercury Oxidization: **Hg(0)** → **Hg(2+)**

Mercury Absorption/Adsorption: in the existing PCD and scrubber


- ▶ Injection location and temperature: Economizer outlet (> **650°F**) or PCD outlet (**320°F**)

EMO® Injection General Arrangements



- ▶ the **X** ppmv of EMO® injection rate was precisely determined by direct sample titration

Flue Gas Flow Analysis



► Oxidization efficiency at the scrubber inlet:

Phase 3: **98%**;


Phase 2: **88%**;

Phase 1: **80%**;


Reference Unit 1 Testing Arrangement



- ▶ 440 MW, ESP +FGD, 100% Lignite




EMO® Phase I Overview (11/14/2011-11/17/2011)




- ▶ Hg content in coal varied between **15.1** and **22.4** lb/TBtu, averaged at **18.0** lb/TBtu

EMO® Phase II Overview (5/22/2012 – 6/12/2012)



▶ Hg content in coal varied between **26.6** and **54.1** lb/TBtu, averaged at **33.7** lb/TBtu, Phase 1: **18.0** lb/TBtu

Reference Unit 1 Economics Analysis



- ▶ The cost estimates for **the first 3 non-EMO™ injection options** were based on Hg Content in coal ~20 lb/TBtu. **None of them demonstrated MATS compliance!**

Stack Visible blue plum – SO₃ Interferences




- ▶ From various CB&I EMO field trial, SO₃ has been observed to inhibit Hg oxidation Hg²⁺ adsorption across the ESP, and Hg²⁺ absorption across the FGD

SO₃ Interferences on Hg - Unit 1 ESP



Unit Configuration: 320 MW burning 100% PRB. SCR + CESP




SO₃ Interferences on Hg - Unit 1 ESP




Date	Unit Load	Max. Hg From PRB	EMO™ Injection Rate	PAC Injection Rate	SO ₃ Injection Rate	NH ₃ Injection Rate	Stack Hg	Stack Hg	Hg Oxidization at Stack	Overall Hg Removal	NO _x	Opacity
mm/dd/yy	(MW)	(lb/TBtu)	(ppmvd)	(lb/mmcf)	(ppmvd)	(lb/hr)	(lb/TBtu)	(lb/GWh)	(%)	(%)	(lb/MMBtu)	(%)
5/2/11	329	7.8	0.0	0	4	223	3.20	0.03122	59.0%	59.0%	0.044	23.9
	329	7.8	0.0	0	4	216	3.40	0.03317	56.4%	56.4%	0.042	23.7
5/3/11	338	11.3	7.6	0	4	232	0.91	0.00888	93.1%	91.9%	0.043	19.0
	338	11.1	5.2	0	0	236	0.77	0.00751	94.5%	93.1%	0.045	17.4
	338	11.3	10.1	0	0	250	0.65	0.00634	95.8%	94.2%	0.045	15.0
5/4/11	348	6.0	4.3	0	0	252	0.50	0.00488	93.1%	91.6%	0.045	17.0
	317	6.0	7.5	0	0	214	0.56	0.00546	93.1%	90.6%	0.045	16.2
5/5/11	342	7.2	3.3	0	0	230	0.78	0.00761	91.3%	89.1%	0.047	20.8
	342	7.2	2.5	0	0	233	1.15	0.01122	85.6%	83.9%	0.046	21.8
5/6/11	345	5.0	5.3	0	0	252	0.43	0.00420	91.4%	91.4%	0.047	20.4
	346	5.0	4.8	0	0	249	0.47	0.00459	90.6%	90.6%	0.048	21.0
5/6/11	315	5.0	4.8	0	0	207	0.38	0.00371	92.8%	92.4%	0.048	16.8
5/7/11	346	7.0	6.0	0	0	226	0.78	0.00761	89.1%	88.9%	0.047	22.0
	341	7.0	5.2	0	0	225	1.04	0.01015	85.7%	85.1%	0.046	26.4
5/8/11	204	6.6	4.9	0	0	142	0.74	0.00722	92.4%	88.8%	0.039	6.3
	204	6.6	5.3	0	0	141	0.34	0.00332	97.4%	94.8%	0.038	5.6
5/9/11	340	8.9	6.6	0	4	207	1.52	0.01483	84.2%	83.0%	0.048	21.6
	340	8.9	8.1	0	4	201	2.02	0.01971	78.9%	77.4%	0.050	25.2
	341	8.9	6.1	0	4	207	2.06	0.02010	77.7%	77.0%	0.051	24.1
5/10/11	281	10.1	6.7	0	6	160	1.36	0.01327	87.0%	86.5%	0.048	15.7
	341	10.1	12.9	0	0	201	1.76	0.01717	83.3%	82.6%	0.048	25.5
5/11/11	299	7.4	13.6	0	0	158	0.73	0.00712	90.2%	90.2%	0.047	15.8
	299	7.4	13.2	0	0	171	0.67	0.00654	91.1%	90.9%	0.047	14.3
5/11/11	335	7.4	12.9	0	0	187	1.40	0.01366	82.7%	81.1%	0.051	23.1
	339	7.4	9.7	2	0	205	0.60	0.00585	94.1%	91.9%	0.051	26.2
5/12/11	338	9.6	0.0	10	4	194	0.58	0.00566	95.8%	94.0%	0.048	24.5
	324	9.6	0.0	10	4	185	0.59	0.00576	95.6%	93.9%	0.048	26.1

SO₃ Interferences on Hg - Unit 2 FGD – Phase 1




- ✓ Hg in coal: 10 lb/TBtu, Sulfur in coal: 3.5%, Stack SO₃ was visible – more than 20 ppmv
- ✓ Baseline stack Hg (T): **1.5 lb/TBtu**,
- ✓ **3.0 ppmv** of EMO at FFBH outlet, Hg (T): **1.1 lb/TBtu**
- ✓ Hydrated Lime was injected 60' downstream of the EMO injection, the main purpose was for SO₃ mitigation
- ✓ **1.5 ppmv** of EMO at the FFBH outlet and **800 lb/hr** of HL at the ID outlet Hg (T): **0.9 lb/TBtu, \$458K/year**

SO₃ Interferences on Hg - Unit 2 FGD - Phase 1




SO₃ Interferences on Hg - Unit 2 FGD - Phase 2




- ✓ Hg in coal: 10 lb/TBtu, Sulfur in coal: 3.5%, Stack SO₃ was visible – more than 20 ppmv
- ✓ Baseline stack Hg (T): **1.8 lb/TBtu**,
- ✓ Hydrated Lime was injected 60' downstream of the EMO injection, the main purpose was for SO₃ mitigation
- ✓ **1.5 ppmv** of EMO at the FFBH outlet and **800 lb/hr** of HL at the ID outlet Hg (T): **0.7 lb/TBtu**, **\$458K/year**

SO₃ Interferences on Hg - Unit 2 FGD - Phase 2







SO₃ Interferences vs. Stack Hg







- ✓ The Ca(OH)₂ injection has been varied to keep the Stack SO₃ < 3 ppmv
- ✓ EMO injection has been kept at 1.5 ppmv on average throughout the entire project, **\$458K/year**


EMO's Co-benefit for Reducing ABS across APH



Ammonium bisulfate	
	
	
Properties	
Molecular formula	(NH ₄)HSO ₄
Molar mass	115.11 g/mol
Appearance	White solid
Density	1.78 g/cm ³
Melting point	147 °C, 420 K, 297 °F
Solubility in water	Very soluble
Solubility in other solvents	Soluble in methanol insoluble in acetone


Ammonium bromide	
	
	
Properties	
Molecular formula	NH ₄ Br
Molar mass	97.94 g/mol
Appearance	white powder, hygroscopic
Density	2.429 g/cm ³
Melting point	452 °C, 725 K, 846 °F
Solubility in water	60.6 g/100 mL (0 °C) 78.3 g/100 mL (25 °C) 145 g/100 mL (100 °C)
Refractive index (n _D)	1.712

EMO's Co-benefit for Reducing ABS across APH



- ▶ Ammonia (NH₃) content of fly ash increased concurrent with EMO injections. At **12.4** ppmv of EMO injection, the NH₃ in the fly ash was observed to increase by **200%**

EMO's Co-benefit for Reducing ABS across APH



▶ As EMO™ increased, the total NH3 in ash increased, Baseline: **28** ppm; EMO Optimal: **97** ppm; increased by **246%**

Can Ca(Br)₂ Produce the Same Results? Not Really



Sampling Date	Test Condition	Start Time	End Time	CaBr ₂ Target ppm	EMO Target ppmvd	Hydrogen Bromide		Relative Deviation %	Hg Oxidization Efficiency %	Stack Hg Removal Efficiency %
						M26A FGD inlet ppmvd	M26A Stack ppmvd			
7/12/2012	EMO - Baseline	9:00	10:00	0	0	0.18	0.10		17%	25%
7/12/2012	EMO - Baseline	11:15	12:15	0	0	0.09	0.10		6%	21%
7/12/2012	EMO Parametric	17:00	18:00	0	2.9	4.48	0.10	21%	54%	57%
7/13/2012	EMO Parametric	10:40	11:40	0	5.5	5.78	0.10	3%	71%	60%
7/16/2012	Trona - Baseline	8:00	9:00	260	0	3.27	0.10		61%	51%
7/16/2012	Trona - Baseline	9:30	10:30	260	0	3.47	0.10		61%	50%

- ✓ Blending **260** ppm of Ca(Br)₂ blending in coal requires 57 lb/hr Ca(Br)₂ (110 lb/hr of 52% Ca(Br)₂ solution). This equates to 0.28 lb-mol of Ca(Br)₂, which generates **0.56** lb-mol available Br material in flue gas in the form of Br₂ or HBr.
- ✓ For **3.3** ppmv EMO™ injection at 195 MW gross generation, it would require 23.1 lb/hr of HBr injection (48 lb/hr of 48% HBr solution). This equates to **0.29** lb-mol of HBr, which generates 0.29 lb-mol available Br in flue gas.
- ✓ Hence applying Ca(Br)₂ could put approximately **50%** of the Br material to waste (**0.29** lb-mol vs. **0.56** lb-mol),
- ✓ the difference in annual cost is approximately **\$120K** for a 200 MW unit
- ✓ **HBr is a more effective material promoting Hg oxidization**

- ▶ EMO® Injection successfully demonstrated Hg compliance to MATS (>90% plus stack Hg oxidization efficiency), for **Lignite, Bituminous, & Sub-Bituminous**
- ▶ The flue gas SO₃ level has a direct negative impact on the Stack Hg control through ESP and FGD
- ▶ EMO® injection does not create impact for the fly ash beneficial use/disposal (No metal leaching issues observed)
- ▶ EMO reduced ABS formation across the APH to prevent plugging issues – **AS a means of neutralizing the NH3 slip to prevent the APH plugging**
- ▶ EMO® was proven to be **~70%** more cost-effective than PAC injection and **~50%** more cost-effective than other fuel halogen additives, such as Ca(Br₂)

CONTACT

Bobby I.T. Chen

Client Program Manager

+1 865.670.2687 – Direct

+1 865.360.2823 – Cell

bobby.chen@cbi.com

Randall P. Moore

Business Line Manager

+1 865.694.7455 – Direct

+1 865.604.3945 – Cell

randall.moore@cbi.com

