



# EMO®

June 20, 2013

Bobby I.T. Chen  
*Client Program Manager*



# Shaw Group is now Chicago Bridge & Iron



- ▶ Chicago Bridge and Iron (CB&I) has completed the acquisition of the Shaw Group.
- ▶ The effective date of the transaction was February 14, 2013.
- ▶ The combined organization brings the capabilities and experience of over 50,000 employees to the marketplace.
- ▶ Even though Shaw will undergo many changes under our new company, the people remain and will provide the same level of service and dedication to clients as before.




# MATS Overview



Subcategory	Total Filterable Particulate Matter (PM)	Hydrogen Chloride (HCl)	Mercury (Hg)
Existing coal-fired unit designed for coal > 8,300 Btu/lb	<b>0.030</b> lb/MMBtu (0.30 lb/MWh)	<b>0.0020</b> lb/MMBtu (0.020 lb/MWh)	<b>1.2</b> lb/TBtu (0.010 lb/GWh)
Existing coal-fired unit designed for coal < 8,300 Btu/lb	<b>0.030</b> lb/MMBtu (0.30 lb/MWh)	<b>0.0020</b> lb/MMBtu (0.020 lb/MWh)	<b>4.0</b> lb/TBtu (0.040 lb/GWh)

- ▶ Mercury and Air Toxics Standard (MATS) published on 2/16/2012, which became effective 60 days later. Compliance needs to be demonstrated by the 1<sup>st</sup> quarter of 2015
- ▶ Final PM limit for Filterable PM only (per EPA Method 5)
- ▶ Use of the alternate SO<sub>2</sub> limit is not allowed if EGU does not have some form of FGD system and SO<sub>2</sub> CEMS installed.
- ▶ Where alternate limits are designated with “or” in Table 2 Section 1 of MATS, these pollutants may be used in lieu of pollutants listed in same subsection (e.g. Total non-HAPs may be used in lieu of Filterable PM).
- ▶ The Hg limit is **based on a 30-day boiler operations rolling average**

# EMO® Injection General Arrangements




- ▶ Injecting chemical: EMO® chemical additives
  - Mercury Oxidation:  $\text{Hg}(0) \rightarrow \text{Hg}^{(2+)}$
  - Mercury Absorption/Adsorption: in the existing PCD and scrubber
- ▶ Injection location and temperature: Economizer outlet ( $> 650^{\circ}\text{F}$ ) or PCD outlet ( $320^{\circ}\text{F}$ )

# EMO® Injection General Arrangements



- ▶ the **X** ppmv of EMO® injection rate was precisely determined by direct sample titration


# Flue Gas Flow Analysis



# Reference Unit 1 Testing Arrangement



- ▶ 220 MW, ESP only, 100% PRB



# Reference Unit 1 Hg Data Overview




Date	Unit Load	Max. Hg From PRB	EMO™ Injection Rate	PAC Injection Rate	Trona Injection Rate	Stack Hg	Stack Hg	Hg Oxidization at Stack	Overall Hg Removal	NOx	Opacity
mm/dd/yy	(MW)	(lb/TBtu)	(ppmvd)	lb/mmacf	(lb/Hr)	(lb/TBtu)	(lb/GWh)	(%)	(%)	(lb/MMBtu)	(%)
5/27/12	236	7.8	0.0	0	0	7.50	0.07317	3.8%	3.8%	0.044	4.5
	235	7.8	0.0	0	0	7.90	0.07707	6.4%	-1.3%	0.042	4.5
6/7/12	234	7.8	4.4	0	0	1.49	0.01457	97.4%	80.9%	0.043	4.2
	237	7.8	6.5	0	0	1.16	0.01136	97.7%	85.1%	0.045	3.4
6/8/12	235	7.8	5.5	0	1200	3.66	0.03570	91.7%	53.1%	0.045	3.6
6/8/12	235	7.8	10.0	2	1200	0.60	0.00585	99.0%	92.3%	0.045	3.5

- ▶ Baseline Hg emission at the Stack, **7.73** lb/TBtu on average, with above **95%** Hg (0)
- ▶ EMO was observed to produce above **96.5%** Hg oxidation efficiency, improved from **5%**
- ▶ EMO was observed to produce above **83.5%** overall Hg removal efficiency
- ▶ Combined with Trona, EMO still produced Hg oxidation rat **91.7%** Hg oxidation efficiency, overall Hg removal efficiency decreased down to **53.1%**
- ▶ Combined with Trona/PAC, EMO produced Hg oxidation rat **99.0%** Hg oxidation efficiency, overall Hg removal efficiency was determined at **92.3%**

# Reference Unit 2 Testing Arrangement



- ▶ 190 MW, SCR +ESP +FGD, 100% Bituminous



# Reference Unit 2 Hg Data Overview



Date	End Time	Unit Load	Max. Hg in Coal	EMO Injection Rate	FGD inlet Hg (0)	FGD inlet Total Hg	ESP Hg Removal	Hg Oxidization FGD Inlet	Stack Hg (0)	Stack Total Hg	Overall System Hg Removal
mm/dd/yy	(HH:MM)	(MW)	(lb/TBtu)	(ppmvd)	(lb/TBtu)	(lb/TBtu)	(%)	(%)	(lb/TBtu)	(lb/TBtu)	(%)
8/16/12	12:30	191.0	5.9	0	0.84	4.30	27.3%	85.9%	1.15	1.15	80.5%
	14:35	190.9	5.9	0	0.94	3.99	32.4%	58.3%	1.49	1.49	74.8%
8/17/12	12:00	190.8	6.5	3.8	0.44	2.66	58.7%	93.2%	0.58	0.58	91.0%
	15:00	191.0	6.5	7.4	0.00	3.16	51.0%	100.0%	0.64	0.72	88.8%
	17:30	191.2	6.5	9.8	0.00	3.13	51.5%	100.0%	0.61	0.71	89.0%
8/18/12	12:00	190.8	6.8	3.4	0.10	3.72	45.2%	98.5%	0.81	0.89	86.8%
	15:00	190.8	6.8	2.9	0.10	3.83	43.5%	98.6%	0.75	0.81	88.0%

- ▶ The optimal EMO® rate was further reduced down to **3.2** ppmv
- ▶ Baseline Hg oxidation efficiency at the FGD inlet : **72.1%**; Baseline overall Hg removal efficiency: **77.7%**
- ▶ Stack Hg (0): **1.32** lb/TBtu, Hg (T): **1.32** lb/TBtu
- ▶ EMO® optimal at **3.2** ppmv: Hg oxidation efficiency at the FGD inlet : **96.8%**; Overall Hg removal: **88.6%**:
- ▶ Stack Hg (0): **0.71** lb/TBtu, Hg (T): **0.76** lb/TBtu

# Reference Unit 2 Hg Data Overview



Date	End Time	Unit Load	Max. Hg in Coal	EMO Injection Rate	FGD inlet Hg (0)	FGD inlet Total Hg	ESP Hg Removal	Hg Oxidization FGD Inlet	Stack Hg (0)	Stack Total Hg	Overall System Hg Removal
mm/dd/yy	(HH:MM)	(MW)	(lb/TBtu)	(ppmvd)	(lb/TBtu)	(lb/TBtu)	(%)	(%)	(lb/TBtu)	(lb/TBtu)	(%)
8/16/12	12:30	191.0	5.9	0	0.84	4.30	27.3%	85.9%	1.15	1.15	80.5%
	14:35	190.9	5.9	0	0.94	3.99	32.4%	58.3%	1.49	1.49	74.8%
8/17/12	12:00	190.8	6.5	3.8	0.44	2.66	58.7%	93.2%	0.58	0.58	91.0%
	15:00	191.0	6.5	7.4	0.00	3.16	51.0%	100.0%	0.64	0.72	88.8%
	17:30	191.2	6.5	9.8	0.00	3.13	51.5%	100.0%	0.61	0.71	89.0%
8/18/12	12:00	190.8	6.8	3.4	0.10	3.72	45.2%	98.5%	0.81	0.89	86.8%
	15:00	190.8	6.8	2.9	0.10	3.83	43.5%	98.6%	0.75	0.81	88.0%

- ▶ Hg content in coal was observed to vary between **5.9** and **6.8** lb/TBtu
- ▶ Hg re-emission was observed during the baseline testing: FGD inlet Hg(0): **0.89** lb/TBtu; Stack Hg (0): **1.32** lb/TBtu
- ▶ At the Optimal EMO® at **3.2** ppmv, Hg Reemission was observed to improve
- ▶ FGD inlet Hg(0): **0.21** lb/TBtu; Stack Hg (0): **0.71** lb/TBtu

# Fly Ash Analysis and other MATS Compliance




Sample Name	Date (2012)	Hg Concentration (ppm)	TCLP Metals, mg/L								% Loss On Ignition
			Arsenic	Barium	Cadmium	Chromium	Lead	Mercury	Selenium	Silver	
Unit 33 FA Hopper#6 8/16/12	8/16	0.111	<0.0125	0.396	<0.0125	0.025	<0.0125	<0.002	0.041	<0.0125	4.11
Unit 33 FA Hopper#6 8/17/12	8/17	0.180	<0.0125	0.404	<0.0125	0.038	<0.0125	<0.002	0.066	<0.0125	9.88
Unit 33 FA Hopper#6 8/18/12	8/18	0.130	<0.0125	0.402	<0.0125	0.030	<0.0125	<0.002	0.077	<0.0125	6.01
Unit 33 FA Hopper#11 8/16/12	8/16	0.030	<0.0125	0.184	<0.0125	<0.0125	<0.0125	<0.002	<0.0125	<0.0125	10.2
Unit 33 FA Hopper#11 8/17/12	8/17	0.044	<0.0125	0.191	0.016	<0.0125	<0.0125	<0.002	<0.0125	<0.0125	24.5
Unit 33 FA Hopper#11 8/18/12	8/18	0.036	<0.0125	0.746	<0.0125	<0.0125	<0.0125	<0.002	0.023	<0.0125	7.39
Reg. Limit (mg/L)			5.0	100	1.0	5.0	5.0	0.2	1.0	5.0	

- ▶ None of the fly ash sample failed the National TCLP requirements on the metals
- ▶ None of the Method 5 runs were observed to fail the MATS PM compliance limit of **0.03** lb/MMBtu: The stack FPM was improved by **37.8%** at the Optimal EMO® at **3.2** ppmv
- ▶ None of the Method 26A runs were observed to fail the MATS HCl compliance limit of **0.002** lb/MMBtu
- ▶ The material cost for continuous EMO® injection at **3.2** ppmv for this reference unit is estimated at **\$438K** per year


# Reference Unit 3 Testing Arrangement



- ▶ 440 MW, ESP +FGD, 100% Lignite




# EMO® Phase I Overview (11/14/2011-11/17/2011)




- Hg content in coal varied between 15.1 and 22.4 lb/TBtu, averaged at 18.0 lb/TBtu

# EMO® Phase II Overview (5/22/2012 – 6/12/2012)



- Hg content in coal varied between **26.6** and **54.1** lb/TBtu, averaged at **33.7** lb/TBtu, Phase 1: **18.0** lb/TBtu

# Reference Unit 3 Economics Analysis




- The cost estimates for **the first 3 non-EMO™ injection options** were based on Hg Content in coal ~20 lb/TBtu. **None of them demonstrated MATS compliance!**

# EMO's Co-benefit for Reducing ABS across APH




Ammonium bisulfate		Ammonium bromide	
Properties		Properties	
Molecular formula	(NH <sub>4</sub> )HSO <sub>4</sub>	Molecular formula	NH <sub>4</sub> Br
Molar mass	115.11 g/mol	Molar mass	97.94 g/mol
Appearance	White solid	Appearance	white powder, hygroscopic
Density	1.78 g/cm <sup>3</sup>	Density	2.429 g/cm <sup>3</sup>
Melting point	147 °C, 420 K, 297 °F	Melting point	452 °C, 725 K, 846 °F
Solubility in water	Very soluble	Solubility in water	60.6 g/100 mL (0 °C) 78.3 g/100 mL (25 °C) 145 g/100 mL (100 °C)
Solubility in other solvents	Soluble in methanol insoluble in acetone	Refractive index ( $n_D$ )	1.712

# EMO's Co-benefit for Reducing ABS across APH



- Ammonia (NH<sub>3</sub>) content of fly ash increased concurrent with EMO injections. At **12.4** ppmv of EMO injection, the NH<sub>3</sub> in the fly ash was observed to increase by **200%**

# Unit 1 NH<sub>3</sub> Analyses – Fly Ash/ FGD Slurry



- As EMO™ increased, the total NH<sub>3</sub> in ash increased, Baseline: **28** ppm; EMO Optimal: **97** ppm; increased by **246%**

# Can Ca(Br)2 Produce the Same Results? Not Really



Sampling Date	Test Condition	Start Time	End Time	CaBr2 Target	EMO Target	Hydrogen Bromide		Relative Deviation	Hg Oxidization Efficiency	Stack Hg Removal Efficiency
						M26A	FGD inlet			
				ppm	ppmvd	ppmvd	ppmvd	%	%	%
7/12/2012	EMO - Baseline	9:00	10:00	0	0	0.18	0.10		17%	25%
7/12/2012	EMO - Baseline	11:15	12:15	0	0	0.09	0.10		6%	21%
7/12/2012	EMO Parametric	17:00	18:00	0	2.9	4.48	0.10	21%	54%	57%
7/13/2012	EMO Parametric	10:40	11:40	0	5.5	5.78	0.10	3%	71%	60%
7/16/2012	Trona - Baseline	8:00	9:00	260	0	3.27	0.10		61%	51%
7/16/2012	Trona - Baseline	9:30	10:30	260	0	3.47	0.10		61%	50%

- ✓ Blending **260** ppm of Ca(Br)2 blending in coal requires 57 lb/hr Ca(Br)2 (110 lb/hr of 52% Ca(Br)2 solution). This equates to 0.28 lb-mol of Ca(Br)2, which generates **0.56** lb-mol available Br material in flue gas in the form of Br2 or HBr.
- ✓ For **3.3** ppmv EMO™ injection at 195 MW gross generation, it would require 23.1 lb/hr of HBr injection (48 lb/hr of 48% HBr solution). This equates to **0.29** lb-mol of HBr, which generates 0.29 lb-mol available Br in flue gas.
- ✓ Hence applying Ca(Br)2 could put approximately **50%** of the Br material to waste (**0.29** lb-mol vs. **0.56** lb-mol),
- ✓ the difference in annual cost is approximately **\$120K** for a 200 MW unit
- ✓ **HBr is a more effective material promoting Hg oxidation**

## Observations & Recommendations



- ▶ EMO® Injection successfully demonstrated Hg compliance to MATS **>90% plus stack Hg oxidation efficiency**, for **Lignite, Bituminous, & Sub-Bituminous**
- ▶ EMO® has been repeatedly observed to Improve Hg re-emission across the scrubber with a means of precise control
- ▶ EMO® injection does not create impact for the fly ash beneficial use/disposal (No metal leaching issues observed)
- ▶ EMO reduced ABS formation across the APH to prevent plugging issues
  - **AS a means of neutralizing the NH<sub>3</sub> slip to prevent the APH plugging**
- ▶ EMO® was proven to be **~70%** more cost-effective than PAC injection and **~50%** more cost-effective than other fuel halogen additives, such as Ca(Br<sub>2</sub>)



## CONTACT

**Bobby I.T. Chen**

*Client Program Manager*

+1 865.670.2687 – Direct

+1 865.360.2823 – Cell

[bobby.chen@cbi.com](mailto:bobby.chen@cbi.com)

**Randall P. Moore**

*Business Line Manager*

+1 865.694.7455 – Direct

+1 865.604.3945 – Cell

[randall.moore@cbi.com](mailto:randall.moore@cbi.com)

