

# Dry Sorbent Injection and Gas Co-Fire / FLGR for Small to Medium Plants

**McIlvaine Hot Topic Hour:** 

Dry Sorbents and Systems and Material Handling in Coal-fired Power Plants

Presented by: Chetan Chothani

JUNE 7 / 2012

### The Balance of Power

CE ISSUES, MANAGIN



**Regulations:** MATS **CSAPR** NAAQS **Coal Residuals** Wastewater **GHG BACT** 

HF BALANCE OF POW

BALANCE-OF-PLANT INPACTS-EMISSIONS CONTROL, PROFILABILITY Fuel Flexibility (Coal V/S Gas) Cost of Compliance **Retire Plants?** 

### **Regulatory Compliance**



#### • MATS (in effect)

- HCI (0.002 Lb/MMBtu) (SO<sub>2</sub> Surrogate 0.2 lb/MmBtu)
- Hg (1,2 Lb/Tbtu)
- PM (0.03 lb/MMBtu)

### CSAPR (Currently Stayed)

- SO<sub>2</sub> (Reduction of Approx 50 to 60 % from 2005 Levels)
- NO<sub>x</sub> (Reduction of Approx 40 to 50 % from 2005 Levels)

### Plants with SCR + Scrubber



#### • MATS

- HCI (Scrubber)
- Hg (SCR Oxidizes; Scrubber Captures)
  - ACI to Augment as necessary; DSI can help with SO<sub>3</sub> interference
- PM (SO<sub>3</sub> contributes to Method 5)
  - DSI can help

### • CSAPR

- SO<sub>2</sub> (Scrubber)
- NO<sub>x</sub> (SCR)

### • In general, there is a path to compliance

## Plants without SCR & Scrubber

Typically 300 MW and below



#### • MATS

- HCI (*DSI*)
- Hg (ACI + DSI for  $SO_3$ )
- PM (DSI for  $SO_3$ )

### CSAPR

- SO<sub>2</sub> (*DSI*?)
  - Sodium Bicarb can deliver 90% reduction. ESP Loading and Flyash sales are a concern
  - Hydrated Lime can deliver 50 to 70% reduction. ESP Loading is a concern
- NO<sub>x</sub> (SNCR?)
  - SNCR performance is limited to less than 30% and inconsistent based on temperature fluctuations and boiler operations

#### In general, not many good options available. DSI is not viable by itself.

### **Component Approach**



# Maybe a Sequential Approach would work?

- Convert some heat input to gas to realize SO<sub>2</sub> and NO<sub>x</sub> reductions and take advantage of lower fuel pricing
- Couple the entire combustion output with FLGR to reduce Nox with an additional SO<sub>2</sub> drop,
- Polish the SO<sub>2</sub> with DSI now that the net particulate is reduced





**Partial Natural Gas Conversion** 

**Natural Gas Co-Fire** 

### Co-Fire?



### • Uses Existing Major Assets:

- No Heat Transfer Modifications or Derates required
- Allows for Fuel Flexibility as Coal/Gas Pricing moves

### Dispatch Consideration

- Gas in Upper Registers can improve Load Ramp and Superheat Temperature control
- Gas In upper registers may allow for reduced MSL

### Co-Firing will require flexible modifications to burners

- Should be accomplished mill by mill
- Introduction of natural gas ports surrounding the main coal pipe



**Fuel Lean Gas Reburn** 

### Fuel Lean Gas Reburn (FLGR)



• Injects 3 to ~10% of Fuel into Upper Furnace





- Natural Gas Injected in Upper Furnace in amount sub stoichiometric to total flue gas oxygen,
- Localized gas pockets create fuel RICH zone where  $CH_4$  reduces  $NO_x$  to  $NH + CO + H_2O$
- Upon re-entrance into O<sub>2</sub> rich zones, CO completes to CO<sub>2</sub>
- When passing the 1750 F temperature zone, some NH compound provides a secondary SNCR action

### 13 Installations – Proven Performance







FLGR Performance:

Up to 30% NO<sub>x</sub>

Amine-Enhanced FLGR (AE-FLGR) can deliver 50% NO<sub>x</sub> reduction

SO<sub>2</sub> equal to Gas Rate



**Dry Sorbent Injection** 

### **Hydrated Lime/Sodium Bicarbonate**

### Equipment and Layout





### Equipment and Layout





### DSI for SO<sub>2</sub>



#### • A Great deal is known about this work:

- Removal rates up to 90+% with SBC
- Removal rates between 50% and 70% with Hydrate
- Effects on fly ash utilization potential
- Effects on particulate collection system
- Effects on ash handling system

# 50% 🗖

#### • Co-Fire @ 25%

- SO<sub>2</sub> Reduction: 25%
- NO<sub>x</sub> Reduction: 20%
- Flyash reduction: 25%





Target

Ν

Ο

Χ

S

0

2

60%

### Achieving Compliance : FLGR





#### • Gas Injection Rate @ 10%

- SO<sub>2</sub> Reduction: 10%
- NO<sub>x</sub> Reduction: 30%
- Flyash Reduction: 10%

# of DSI <= reduction in flyash

**Additional Particulate loading** 



SO<sub>2</sub> reduction required = 25% of base or 40% of remaining

**Easily achieved by DSI** 

Achieving Compliance : DSI





60%

Target

### Other benefits of Gas Co-Fire



#### Hidden advantages

- Improved load following and low load turn-down,
- Improved ignition system and warm-up,
- Increased peaking, and Unit capacity & reliability,
- Better SH/RH control,
- Reduced fan loading of both primary & secondary fans,
- Reduced fuel inventory,
- More uniform and increased flame zone O<sub>2</sub>,
- Consequently reduced slag formation problems.

#### Operating advantages

- Lower O<sub>2</sub> operation,
- Reduced SO<sub>3</sub>, acid, air-heater, back-end and plume problems,
- Reduced LOI, leading to cleaner ash and better ESP operation,
- More salable ash,
- Dedicated fuel supply contracts.



- DSI is a useful technology for HCI and SO<sub>3</sub> mitigation for plants with SCR and Scrubber
- DSI can be a viable technology for compliance for plants without an SCR and Scrubber as part of a package that includes Gas Co-Fire and FLGR

### **Questions?**