



Amerex...

Forward Thinking Air Emission Solutions

Prepared for: McIlvaine Hot Topic Hour

Industrial MACT—Impact and Control Options

November 18, 2010




Who is Amerex?

Air Emission Compliance Solutions Company

- APC for SO_x, PM, Hg, HCl, HAPs
- Complete “Value Chain”—Audit, Assessment, Strategy, Engineering, Installation, Training, Aftermarket
- Key Personnel average 28 years in APC Industry
- “ Rebrand” Amerex (2010) → Smart ComplianceSM

Smart Compliance System



Proposed MACT Standards: Existing and New Coal-Fired Boilers

Existing Boilers

Coal Boilers (burning at least 10% coal or petcoke)


Compound	Original Existing MACT Limit	Proposed Rule	Units
PM	0.07	0.02	lb/MMBtu
HCl	0.09	0.02	lb/MMBtu
Hg	9E-06	3E-06	lb/MMBtu
Dioxin (TEQ basis) (no limit under original MACT)	Stoker/grate/other	0.003	TEQ ng/dscm @ 7% O ₂
	Pulverized Coal	0.004	TEQ ng/dscm @ 7% O ₂
	Fluidized Bed	0.002	TEQ ng/dscm @ 7% O ₂
Carbon Monoxide (no limit under original MACT for existing)	Stoker/grate/other	50	ppm @ 3% O ₂ as Propane
	Pulverized Coal	90	ppm @ 3% O ₂ as Propane
	Fluidized Bed	30	ppm @ 3% O ₂ as Propane

New Boilers


Coal Boilers

Compound	Original MACT Limit	Proposed Rule	Units
PM	0.025	0.001	lb/MMBtu
HCl	0.02	6E-05	lb/MMBtu
Hg	3E-06	2E-06	lb/MMBtu
Dioxin (TEQ basis) (no limit under original MACT)	Stoker/grate/other	0.003	TEQ ng/dscm @ 7% O ₂
	Pulverized Coal	0.002	TEQ ng/dscm @ 7% O ₂
	Fluidized Bed	3E-05	TEQ ng/dscm @ 7% O ₂
CO (original new MACT limit of 400)	Stoker/grate/other	7	ppm @ 3% O ₂ as Propane
	Pulverized Coal	90	ppm @ 3% O ₂ as Propane
	Fluidized Bed	30	ppm @ 3% O ₂ as Propane

Amerex Compliance Technologies for Boiler MACT




Dry Scrubbing Systems – Carbon, Lime Trona and SBC




Industry	Dry Process	Pollutants	Reagent	Removal
Incineration and Coal Fired Boilers	Simple Venturi	HCl	Lime/Sodium	95%/99%
		SO ₂	Lime/Trona/Sodium	< 35%/95%
		Dioxin	Carbon	+ 99%
		Hg ⁽¹⁾	Carbon	60% – 90%

Performance of Trona in SO₂ Mitigation



@ 80% SO₂ Removal
HCl Removal is 98%
With NSR of 1.0

Performance of Sodium Bicarbonate in SO₂ Mitigation



@ 80% SO₂ Removal
HCl Removal is 98%
With NSR of 1.0

Semi-Dry/Spray Dryer Absorber System



KEY

- F1 Gas From Boiler
- F2 Atomizing Air
- F3 Shroud Air
- F4 Filter Inlet
- F5 In-leakage/Pulse Air
- F6 Filter Outlet


- S1 Ca(OH)₂ Feed shown in L2
- S2 Grit Discharge – not used
- S3 SD/A Discharge
- S4 Filter Discharge
- S5 System Discharge

- L1 Slaker H₂O – not used
- L2 Slurry Feed
- L3 Dilution Water
- L4 SD/A Feed

Boiler MACT

99+% HCl Removal
Outlet to 2 ppm(v)


First Reported Dioxin/Furan
Less than detectable limit




Pulse Jet Fabric Filters





Full Height Outlet Plenum with walk-in access for weather tight maintenance and corrosion resistance



Tuned Blowtubes with varied hole diameters for balanced cleaning performance




Baffled Inlet for even flow distribution



Pulse Jet


- Split Hopper/Side Ash Laden Gas Entry
- Outside of Bag Ash Collection
- Tube Sheet Suspension/Anti-Collapse Cage
- On-line Cleaning via Compressed Air Jet
- Typical 4:1 (ft/min) Air-to-Cloth Ratio
- Felt Filter Bags + Optional PTFE Membrane



CLEANING SYSTEM FEATURES


TUNED BLOWTUBE SYSTEM

Orifice size varied according to position relative to valve



*** Curve fit from test data

COMPARTMENT DESIGN





Installation List (2005-Present)

Online Date	Boiler MACT	Client	State	Fuel Type	Equip (E) or Turnkey (T)	Pulse Jet Fabric Filter	Reverse Air	ESP to PJFF	SDA	CFB	Sorbent Injection Systems				ACFM
											B-PAC	Carbon	Lime	Trona	
Aug-05		Menasha Utility	WI	Coal	T			√							2 x 85,000
Sep-05	√	Jim Beam	KY	Coal	E	√							√		1 x 25,000
Jun-07	√	Morton Salt--Rittman	OH	Coal	E	√							√	√	2 x 76,800
Jul-07	√	EI Lilly	IN	Coal	T	√							√		1 x 152,000
Jul-07	√	Morton Salt--Manistee	MI	Coal	E	√							√		1 x 79,300
Sep-07	√	Abbott Laboratories	IL	Coal	E	√							√		2 x 48,000
Oct-07		Barton Brands	KY	Coal	T	√							√		1 x 50,600
Oct-07		Severstal Steel	MI		E	√									1 x 285,000
Feb-08	√	U of Virginia	VA	Coal	E	√			√				√		3 x 45,000
Mar-08	√	Purdue University	IN	Coal	E	√				√					1 x 118,000
Jun-08		New Energy	IN	Coal	T	√				√					1 x 140,000
Jun-08		Wheeling Pittsburgh	PA		E	√									1 x 300,000
Jun-08		KHH Olmstead (Units 1 + 2)	MN	MSW	T	√									2 x 31,000
Jul-08	√	Delphi	MI	Coal	E	√									3 x 72,000
Sep-08	√	Indiana University	IN	Coal	E	√							√	√	2 x 94,821
Feb-09		City of Lakeland	FL	Coal	E								√		1 x 1,072,000
Apr-09	√	Miami University	OH	Coal	E	√				√			√		3 x 60,000
Jun-09		Encore Wire	TX		E	√							√		1 x 33,500
Nov-09		Covanta (Lines 1 + 2)	HI	MSW	E		√								2 x 330,000
Jan-10		WPS (Pulliam)	WI	Coal	T								√		1 x 585,000
Oct-10		Mittal Steel	South Africa		T	√				√					2 x 550,000
Dec-11		Covanta (Line 3)	HI	MSW	E	√			√						1 x 200,737

Selected Results, First Round (2004) Boiler MACT



Site	Boiler	Coal	Equipment	C- Rate (lb/MMACF)	Hg In (lb/TBTU)	Hg Out (lb/TBTU)	SO ₃ (ppmv)
1	Stoker	OH/IN Bit	Dry lime Inj. Carbon Inj Fabric Filter	1.8 B-PAC	30	2.8	1
2	PC	IN Bit	Carbon Inj. Fabric Filter	2.2 B-PAC	20	2.5	2
3	Stoker	IN Bit	Evaporative Cooler Fabric Filter	0	15	6	20
4*	Stoker	Eastern Bit	SD/A Carbon Inj. Fabric Filter	2.0 PAC	25	2	<1

* Dioxin/Furan below detectable limits



Points of Contact

David W. South

Manager, Business Development

630.406.7756 x118

dsouth@amerexind.com

John T. Foster

Exec VP, Sales & Technology

630.406.7756 x111

jfoster@amerexind.com

Tony Andriola

Manager, Industrial Products

630.406.7756 x119

tandriola@amerexind.com