



#### **Progress on High Efficiency Coal Power Plants**


#### **Dr. Jeff Phillips** Sr. Program Manager, Generation

**McIlvaine Webcast** March 1, 2012



*CoalFleet for Tomorrow*<sup>®</sup> is a registered service mark of Electric Power Research Institute, Inc.

## **Materials Limit the Current Technology**



### Primary Technical Goals of US A-USC Materials Programs

- Materials Technology Evaluation
  - Focus on nickel-based alloys
  - Development of fabrication and joining technology for new alloys
- Unique Conditions for US Program Considerations
  - Higher-temperatures than European Program (760 C versus 700 C) means additional alloys are being evaluated
  - Corrosion resistance for US coals
  - Data for **ASME code** acceptance of new materials
  - Phase II Boiler work includes Oxycombustion

Acknowledgements: U.S. Department of Energy (US DOE) / Ohio Coal Development Office (OCDO) A-USC Steam Boiler and Turbine Consortia



Federal – State – National Laboratory

Non Profit – For Profit


**Cost Sharing Consortium** 



ALSTON FOSTER WHEELER WHEELER

MANAGED BY UT-BATTELLE FOR THE DEPARTMENT OF ENERGY

## U.S. DOE/OCDO: A-USC Steam Boiler Consortium



# Major Step: Code Case 2702 (Inconel®740) now Approved for Use in Section I

- Approved: Sept. 26, 2011
- Maximum Use Temperature: 800°C (1472°F)
- Rules for:
  - Chemistry
  - Heat-treatment
  - Welding
  - Post-weld heattreatment
  - Cold-forming
  - Weld strength reduction factors

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

CASE 2702

Approval Date: September 26, 2011

Code Cases will remain available for use until annulled by the applicable Standards Committee.

Case 2702 Seamless Ni-25Cr-20Co Material Section I

Inquiry: May precipitation-hardenable Ni-25Cr-20Co alloy (UNS N07740) wrought sheet, plate, rod, seamless pipe and tube, fittings and forgings material conforming to the chemical requirements shown in Table 1, the mechanical properties listed in Table 2, and otherwise conforming to the applicable requirements in the specifications listed in Table 3 and in this Case be used in welded construction under Section I rules?

Reply: It is the opinion of the Committee that precipitation-hardenable Ni-25Cr-20Co alloy (UNS N07740) wrought sheet, plate, rod, seamless pipe and tube, fittings and forgings as described in the Inquiry may be used in welded construction complying with the rules of Section I, provided the following rules are met:

(a) Material shall be supplied in the solution heat treated and aged condition. Solution heat treatment shall be performed at 2,010°F (1100°C) minimum for 1 hr per 1 in. (25 mm) of thickness but not less than <sup>1</sup>/<sub>2</sub> hr. Aging shall (d) Postweld heat treatment for this material is mandatory. The postweld heat treatment shall be performed at 1,400°F to 1,500°F (760°C to 815°C) for a minimum of 4 hr for thickness up to 2 in. (50 mm), plus an additional 1 hr per additional 1 in. (25 mm) of thickness. If a longitudinal weld seam is required in the construction of a component, a weld strength reduction factor of 0.70 shall apply in accordance with rules in PG-26 for applications at temperatures above 1.112°F (600°C).

(e) After cold forming to strains in excess of 5%; after any swages, upsets, or flares; or after any hot forming of this material, the component shall be heat treated in accordance with the requirements specified in (a). No local solution annealing may be performed. The entire affected component or part that includes the cold-strained area and transition to unstrained material must be included in both heat treatments. The calculations of cold strains shall be made as described in Section I, PG-19.

(f) The maximum use temperature is 1,472°F (800°C).
(g) S<sub>u</sub> and S<sub>y</sub> values are listed in Tables 5 and 5M and Tables 6 and 6M, respectively.

(h) Physical Properties. See also Tables 7 and 7M,

Currently in process for B31.1 – Additional Research Underway to Extend the Maximum Use Temperature

## Highlights: World's First Inconel®740 Pipe Extrusion

 Special Metals (Huntington, WV) & Wyman-Gordon (Houston, TX) Project

not consortium funded

- 15-inch (381mm) O.D. X 8inch (203mm) I.D. X 34-1/2 feet (10.4m) long
- Larger forging window for Inconel 740 compared to CCA617 (same size pipe extrusion was shorter, 8.9m)



Inconel®740 Pipe after Extrusion at Wyman-Gordon

## **1022036 (A-USC Steam Turbine) Highlight:** Large Step Casting Produced

- Research by NETL & ORNL led to selection of key turbine cast alloys for casings & valve bodies
  - Haynes 282 (primary) & Alloy 263
  - Numerous trial plates produced for welding repair studies
- Scale-up Efforts (Haynes 282)
  - 300 lb step casting (Manufacturer 1)
  - 600 lb finished weight step casting (Manufacturer 2 EIO Project)




## 1022036 (A-USC Steam Turbine) Highlight: Cast Nickel-based Alloy Welding Development

- 50.4mm (2") thick cast plates produced
  - 282 and 263
  - Test Plan = tensile, creep, LCF, & impact



#### **Cast Plate During Welding**

## Simulated Casting Defect & Subsequent Casting Repair



#### **1022037 (A-USC Steam Boiler) Highlight:** Fireside Corrosion – Steam Loop

- 1<sup>st</sup> Steam Loop was completed in Phase 1
  - Aggressive high Sulfur coal
  - Did not meet intended temperatures (less than 760°C/1400°F)
- 2<sup>nd</sup> Steam Loop now installed and operating
  - Future press release with more details
  - Goal: 12-18 months of operation
  - Maximum Temperature:
    - 760°C (1400°F)





## **Summary: Excellent Progress in 2011**

- Approval of ASME Code Case 2702 (Inconel ®740)
- Worldwide interest in program results and materials has spurred commercial interest
- Steam-turbine has selected key alloys, extensive testing has started, and scale-up activities have begun
- A utility workshop has helped focus future EPRI and Consortium efforts → AGAG & weld repair studies in boiler & turbine programs






## More to Come in 2012


- Additional field fireside corrosion testing (steam loop)
- Completion of oxycombustion design studies
- Fireside corrosion in oxycombustion environments
- Scale-up activities on turbine to include a larger rotor/disc forging
- Performance of weld repairs

Calculated combustion microclimates for different firing conditions




## **Supercritical CFB**

#### **Katowice**, **Poland**



## PKE Łagisza 460 MWe CFB Power Plant



#### Flue gas to cooling tower

## **Particulars**

#### **100% MCR Design Conditions**

SH Flow	2,860 klb/hr	361 kg/s
SH Pressure	3989 psig	275 bar
SH Temperature	1040 F	560 C
RH Flow	2,424 klb/hr	306 kg/s
RH Pressure	798 psig	55 bar
Cold RH Temperature	599 F	315 C
Hot RH Temperature	1076 F	580 C
Feedwater Temperature	554 F	290 C

#### **Permitted Emissions**

	Concentration mg/Nm <sup>3</sup> (6% O <sub>2</sub> , dry)	Yield lb/MMBtu	Primary control
SO <sub>2</sub>	200	0.14	Limestone @ Ca/S of 2.0-2.4: 94% capture
NO <sub>X</sub>	200	0.14	SNCR - Aqueous $NH_3$ to cyclone inlets
Particulate	30	0.02	ESP

#### **Bituminous coal from many local mines**

LHV	7700-9900 Btu/lb	18-23 MJ/kg
Moisture	6-23%	
Ash	10-25%	
Sulfur	0.6-1.4%	
Chlorine (dry)	< 0.4%	

Steam generator is also designed to burn:

- Up to 30% (by energy) coal slurry
- High ash washery wastes
- Up to 10% (by weight) biomass

#### **Plant Performance**

Gross Plant Output	460 MWe
Auxiliary Power	21 MWe (4.6% gross)
Net Plant Output	439 MWe
Net Plant Heat Rate	8,204 Btu/kWh (HHV) 41.6% net efficiency

## **Together...Shaping the Future of Electricity**