

Post-Combustion
Dry Reagent Injection
For
Acid Gas Mitigation
Boilers and Cement Kilns



**SOUTHERN AIR
SOLUTIONS CORP**

Clearing the air

Dry Reagent Injection

Discussion

- Trona Basics
- Mobile DRI Systems
- Results
 - 550 MW Utility Boiler
 - 150 kpph Industrial Boiler
 - 950 tpd Cement Kiln

Dry Reagent Injection

Trona

SO₂ Stoic Ratio = 2.35 lb trona/lb SO₂

HCl Stoic Ratio = 2.07 lb trona/lb HCl



Dry Reagent Injection

Normalized Stoichiometric Ratio (NSR)

$$NSR = \frac{\left(\frac{\text{mass of trona injected}}{\text{mass of acid gas entering system}} \right)}{\left(\frac{\text{stoichiometric mass of trona}}{\text{unit mass of acid gas}} \right)}$$

Dry Reagent Injection

Parameters Affecting Acid Gas Removal by DRI


- Sorbent particle size (trona as received – 35 μm D50)
- Sorbent residence time in the flue gas stream
- Sorbent dispersion within the flue gas
- Particulate control device used
- Other acid gases (e.g., high SO_2 concentration)

SO_2 %RE and NSR are functions of these parameters

Dry Reagent Injection


Mobile DRI Systems

- Modular – setup in 1 – 2 days
- Milling on-site
- Silos
- Bulk Trailers
- Supersack systems




Dry Reagent Injection

550 MW Utility Boiler w/ ESP - SO₂/HCl vs. NSR




Dry Reagent Injection

550 MW Coal w/ESP - Trona Feed Rate vs. HCl %RE




Dry Reagent Injection

SO₂ and HCl Removal vs. Trona Injection Rate
150 kpph Boiler Biomass/SW with ESP




Dry Reagent Injection

PM Emissions vs. Trona Injection Rate
150 kpph Steam Boiler with ESP




Dry Reagent Injection

PM Emissions and HCl Removal vs. Trona Injection Rate
150 kpph Boiler with ESP




Dry Reagent Injection

SO₂ and HCl Removal vs. Trona Injection Rate
150 kpph Boiler Biomass/SW with ESP



Dry Reagent Injection

Milled Trona SO2 %RE vs. NSR for Cement Kiln with FFBH




Dry Reagent Injection

Operating Unit	Kiln A	Kiln B	Kiln C
Sorbent	Trona	Trona	Trona
APCD	FFBH	FFBH	FFBH
Moisture Content at Stack (%vol)	33.5%	11.5%	16.0%
SO₂ at Stack (ppmvd)	900	110	300
HCl at Stack (ppmvd)	15	15	15
Flue Gas Temperature (F)	350	310	310
Flue Gas Flow Rate (acfm)	160,000	220,000	150,000
Flue Gas Flow Rate (scfm)	104,691	151,429	103,247
Flue Gas Flow Rate (dscfm)	69,620	134,014	86,727
Clinker Produced (ton/day)	950	1,100	1,900
CKD Collection Rate (ton/hr)	5.0	3.5	6.0
CKD Recycled (%)	40%	100%	100%
SO ₂ (lb/hr)	625.0	147.0	259.5
HCl (lb/hr)	5.93	11.42	12.32
HCl (ppmvd @ 7% O₂)	14.0	14.0	23.3
HCl - %RE required to Comply with PC MACT	79%	79%	87%

Dry Reagent Injection

Milled Trona SO2 %RE vs. NSR for Cement Kiln with FFBH



Dry Reagent Injection

Operating Unit	Kiln A	Kiln B	Kiln C
SO ₂ NSR Required	0.45	0.45	0.45
SO ₂ - Corresponding %RE	40%	40%	40%
TOTAL TRONA NEEDED (lb/hr)	672	176	297
Clinker Production (lb/hr)	79,167	91,667	158,333
CKD Recycled (%)	40%	100%	100%
CKD Rate Recycled (lb/hr)	4,000	7,000	12,000
Na ₂ SO ₄ Formed (lb/hr)	555	130	230
NaCl Formed (lb/hr)	10	18	20
Na from Trona Into CKD (lb/hr)	82	54	91
Na Recycled to Kiln (lb/hr)	33	54	91
Na In Clinker from Trona (%wt)	0.041%	0.059%	0.057%
Na ₂ O Equivalent in Clinker from Trona (%wt)	0.056%	0.079%	0.077%

Considerations

- Failed fly ash TCLP for selenium
 - High Se bearing coal
 - High trona injection rates
- Greatly reduced trona usage with baghouse
- Plume coloration at high trona injection rates (NO₂)
- Can boost native Hg removal
- Can increase Hg emissions
- Inorganic CPM emissions increase (CPM expected to be regulated from EU boilers as PM_{2.5})
- Land-filling considerations

Conclusions

- Trona has high reactivity with HCl and SO_x compounds
- Greatly reduced trona usage with baghouse and milling
- Trona can be a solution for EU MATS and Boiler MACT for HCl
- For moderate to low SO₂ flue gases trona may be a solution for PC MACT compliance for kilns recirculating up to 100% of CKD
- For high SO₂ flue gases trona may be a solution but may require wasting more CKD