



Wet ESPs for Advanced Particulate Collection

Presented to McIlvaine Hot Topics Hour

August 1, 2013

Steven A. Jaasund, P.E.

August 1, 2013



E-Tube® system at FM Global in Rhode Island


- **High efficiency PM removal, including sub-micron**
- **Proven solution on many applications**
- **No impediment to gas flow, low pressure drop**
- **Ideal for clean-up after wet scrubber**
- **High uptime, low maintenance**
- **Simple solution, add-on capability**



Wet ESP Technology
A Proven Solution for Particulate Control

- Size has a strong influence on the performance of a wet precipitator in collecting fine particles

- Wet electrostatic precipitators capture fine particles more efficiently than the highest-energy wet scrubbers






Wet ESP Performance Test Results Northwest P&P Mill

- Biomass stoker boiler also burning mill sludge, OCC and TDF
- Tests conducted from 2009 through 2011
- 46 total tests; 23 on each wet ESP unit
- Average outlet emission
 - 0.0032 lb/MM BTU
 - 0.0033 grains/scfd @ 7% O₂

- *First Boiler MACT compliant installation*
 - *Biomass stoker boiler also burning mill sludge, waste oil and OCC*
-
- *46 total tests; 23 on each wet ESP unit*
 - *Avg. 0.0032 lb/MM BTU (0.037 limit)*



Winter 2012 Pilot Test Program

- Test Site – London, England
- Application - Municipal waste-to-energy boiler
- Test Set-up
 - ~1200 scfm (wet) raw gas from upstream of dry ESP
 - Pilot Equipment
 - » Multiclone
 - » Wet scrubber; $\Delta P \sim 15$ inches w.c.
 - » Wet ESP; SCA ~ 100 to $150 \text{ ft}^2/1000 \text{ acf}$
- Inlet Gas Stream Profile
 - $>2000 \text{ mg/Nm}^3$ total particulate
 - $\sim 100 \text{ ppm HCl}$
 - $\sim 75 \text{ ppm SO}_2$



Pilot Test Program Results



- **Particulate Results (11 tests)**

- Solid particulate 0 to 3.0 mg/Nm³; average 1.5 mg/Nm³
- Condensable particulate 0 to 3 mg/Nm³; average 1.5

- **Group II and III Heavy Metals >99% removal**

- **Mercury >90% Removal**

- **Acid Gases**

- HCl < 1.5 ppm
- SO₂ < 1.0 ppm



Steel Mill Pilot Test Program

- **Test Site – Seattle, WA**
- **Application – Slag Pile Cooling Shed**
- **Test Conditions**
 - 5800 acfm (wet) raw gas from slag pile
 - 100°F
 - Wet ESP SCA = 32 ft²/1000 acf
- **Test Results**
 - Inlet – 3.4 mg/Nm³ solid particulate
 - Outlet - < 0.2 mg/Nm³ solid particulate



E-Tube® system at RockTenn

- **Materials of construction**

- Austenitic stainless is minimum

- Duplex alloys are economical upgrade

- High nickel required for most difficult applications

- **Waste water treatment**

- **Wet plume**




E-Tube® Power Off



E-Tube® Power On



Power On/Off



Questions



Wet ESPs for Advanced Particulate Collection

Presented to McIlvaine Hot Topics Hour

August 1, 2013

Steven A. Jaasund, P.E.

steve.jaasund@lundberg-us.com

May 29, 2013